

EMC TEST REPORT

For

Shenzhen SCMK New Energy Co.,Ltd

Solar Inverter

Model No.: VMII Plus 5.5KW

Additional Model No.:SC-MAX 11KW II, VM 1.5K, VM 3K, VMII Plus 3.5KW, VMII Plus 5.5KW,SCMK 3K-24V, MKSII 5K, VMIV 3.6KW, VMIV 5 .6KW, VMIV 4KW,VMIV 6KW, SC-MAX 8KW, SC-MAX 11KW, VII 5KW, VII 10.5KW,VMIV 4.2KW, VMIV 6.2KW, SC-MAX 8KW II

Prepared for : Shenzhen SCMK New Energy Co.,Ltd
Address : Room 703, Building 3, Nam Tai Inno Park. No.759 Tongye Road Tangwei Community Fenghuang Street Guangming District Shenzhen City Guangdong China

Prepared by : Shenzhen AOCE Electronic Technology Service Co., Ltd.
Address : Room 202, 2nd Floor, No.12th Building of Xinhe Tongfuyu Industrial Park, Fuhai Street, Baoan District, Shenzhen, Guangdong, China

Tel : (+86)755-85277785
Fax : (+86)755-23705230
Web : www.aoc-cert.com
Mail : postmaster@aoc-cert.com

Date of receipt of test sample : June 9, 2025
Number of tested samples : 1
Serial number : Prototype
Date of Test : June 9, 2025 - June 20, 2025
Date of Report : June 20, 2025



EMC TEST REPORT

EN IEC 61000-6-3:2021

Emission standard for residential, commercial and light-industrial environments

EN IEC 61000-6-1:2019

Immunity for residential, commercial and light-industrial environments

Report Reference No. : AOC250620110E-R1

Date Of Issue..... : June 20, 2025

Testing Laboratory Name..... : Shenzhen AOCE Electronic Technology Service Co., Ltd.

Address..... : Room 202, 2nd Floor, No.12th Building of Xinhe Tongfuyu Industrial Park, Fuhai Street, Baoan District, Shenzhen, Guangdong, China

Testing Location/ Procedure..... : Full application of Harmonised standards ☒
Partial application of Harmonised standards ☐
Other standard testing method ☐**Applicant's Name..... : Shenzhen SCMK New Energy Co.,Ltd**

Address..... : Room 703, Building 3, Nam Tai Inno Park. No.759 Tongye Road Tangwei Community Fenghuang Street Guangming District Shenzhen City Guangdong China

Test Specification:Standard..... : EN IEC 61000-6-3:2021
EN IEC 61000-3-2:2019+A1:2021
EN 61000-3-3:2013+A1:2019+A2:2021
EN IEC 61000-6-1:2019

Test Report Form No..... : AOCEMC-1.0

TRF Originator..... : Shenzhen AOCE Electronic Technology Service Co., Ltd.

Master TRF..... : Dated 2011-03

Shenzhen AOCE Electronic Technology Service Co., Ltd. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the Shenzhen AOCE Electronic Technology Service Co., Ltd. is acknowledged as copyright owner and source of the material.

Test Item Description..... : Solar InverterTrade Mark..... : 

Model/ Type Reference..... : VMII Plus 5.5KW

Input: AC 90V-280V, 50Hz/60Hz, 38.5A

Ratings..... : PV Input: DC 120-450V, Max.100A

Output: AC 230V, 50Hz/60Hz, 23.9A

Result : Positive**Compiled by:**

David Liu

Supervised by:

Kevin Huang

Approved by:

Jackson Fang

David Liu/ File administrators

Kevin Huang/ Technique principal

Jackson Fang/ Manager

EMC -- TEST REPORT

Test Report No. : AOC250620110E-R1June 20, 2025

Date of issue

Type / Model..... : VMII Plus 5.5KW

EUT..... : Solar Inverter

Applicant..... : Shenzhen SCMK New Energy Co.,LtdAddress..... : Room 703, Building 3, Nam Tai Inno Park. No.759
Tongye Road Tangwei Community Fenghuang Street
Guangming District Shenzhen City Guangdong China

Telephone..... : /

Fax..... : /

Manufacturer..... : Shenzhen SCMK New Energy Co.,LtdAddress..... : Room 703, Building 3, Nam Tai Inno Park. No.759
Tongye Road Tangwei Community Fenghuang Street
Guangming District Shenzhen City Guangdong China

Telephone..... : /

Fax..... : /

Factory..... : Shenzhen SCMK New Energy Co.,LtdAddress..... : Room 703, Building 3, Nam Tai Inno Park. No.759
Tongye Road Tangwei Community Fenghuang Street
Guangming District Shenzhen City Guangdong China

Telephone..... : /

Fax..... : /

Test Result according to the standards on page 6:**Positive**

The test report merely corresponds to the test sample.

It is not permitted to copy extracts of these test result without the written permission of the test laboratory.

TABLE OF CONTENTS	Page
1. SUMMARY OF STANDARDS AND RESULTS	6
1.1.Description of Standards and Results	6
1.2.Description of Performance Criteria	7
2. GENERAL INFORMATION	8
2.1.Description of Device (EUT)	8
2.2.Description of Test Facility	8
2.3.Statement of the measurement uncertainty	8
2.4.Measurement Uncertainty	9
3. MEASURING DEVICES AND TEST EQUIPMENT	10
3.1.Conducted Disturbance	10
3.2.Disturbance Power	10
3.3.Radiated Electromagnetic Disturbance	10
3.4.Radiated Disturbance (Electric Field)	10
3.5.Harmonic Current	10
3.6.Voltage fluctuation and Flicker	10
3.7.Electrostatic Discharge	11
3.8.RF Field Strength Susceptibility	11
3.9.Electrical Fast Transient/Burst	11
3.10.Surge	11
3.11.Conducted Susceptibility	11
3.12.Power Frequency Magnetic Field Susceptibility	12
3.13.Voltage Dips	12
3.14.Voltage Short Interruptions	12
4. RADIATED EMISSION MEASUREMENT	13
4.1.Block Diagram of Test Setup	13
4.2.Test Standard	13
4.3.Radiated Emission Limits	13
4.4.EUT Configuration on Test	14
4.5.Operating Condition of EUT	14
4.6.Test Procedure	14
4.7.Test Results	14
5. ELECTROSTATIC DISCHARGE TEST	16
5.1.Block Diagram of Test Setup	16
5.2.Test Standard	16
5.3.Severity Levels and Performance Criterion	16
5.4.EUT Configuration on Test	16
5.5.Operating Condition of EUT	17
5.6.Test Procedure	17
5.7.Test Results	17
6. RF FIELD STRENGTH SUSCEPTIBILITY TEST	19

6.1.Block Diagram of Test Setup	19
6.2.Test Standard	19
6.3.Severity Levels and Performance Criterion	19
6.4.EUT Configuration on Test	20
6.5.Operating Condition of EUT	20
6.6.Test Procedure	20
6.7.Test Results	20
7. MAGNETIC FIELD IMMUNITY TEST	22
7.1.Block Diagram of Test Setup	22
7.2.Test Standard	22
7.3.Severity Levels and Performance Criterion	22
7.4.EUT Configuration on Test	22
7.5.Operating Condition of EUT	23
7.6.Test Procedure	23
7.7.Test Results	23
8. PHOTOGRAPH	25
8.1.Test Results	25
9. EXTERNAL AND INTERNAL PHOTOS OF THE EUT	26

1. SUMMARY OF STANDARDS AND RESULTS

1.1. Description of Standards and Results

The EUT have been tested according to the applicable standards as referenced below.

EMISSION (EN IEC 61000-6-3:2021)			
Description of Test Item	Standard	Limits	Results
Conducted disturbance at mains terminals	EN 55032: 2015+A11:2020	Class B	N/A
Conducted disturbance at telecommunication port	EN 55032: 2015+A11:2020	Class B	N/A
Radiated disturbance	EN 55032: 2015+A11:2020	Class B	PASS
Harmonic current emissions	EN IEC 61000-3-2:2019+A1:2021	Class A	PASS
Voltage fluctuations & flicker	EN 61000-3-3:2013+A1:2019+A2:2021	-----	PASS
IMMUNITY (EN IEC 61000-6-1:2019)			
Description of Test Item	Basic Standard	Performance Criteria	Results
Electrostatic discharge (ESD)	EN 61000-4-2:2009	B	PASS
Radio-frequency, Continuous radiated disturbance	EN 61000-4-3:2020	A	PASS
Electrical fast transient (EFT)	EN 61000-4-4:2012	B	N/A
Surge (Input a.c. power ports)	EN 61000-4-5: 2014+A1:2017	B	N/A
Surge (Telecommunication ports)		B	N/A
Radio-frequency, Continuous conducted disturbance	EN 61000-4-6: 2014+AC:2015	A	N/A
Power frequency magnetic field	EN 61000-4-8: 2010	A	PASS
Voltage dips, >95% reduction	EN 61000-4-11:2020+AC:2020	C	N/A
Voltage dips, 30% reduction		C	N/A
Voltage interruptions		C	N/A
N/A is an abbreviation for Not Applicable.			

1.2.Description of Performance Criteria

General Performance Criteria

Examples of functions defined by the manufacturer to be evaluated during testing include, but are not limited to, the following:

- essential operational modes and states;
- tests of all peripheral access (hard disks, floppy disks, printers, keyboard, mouse, etc.);
- quality of software execution;
- quality of data display and transmission;
- quality of speech transmission.

1.2.1.Performance criterion A

The equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed below a performance level specified by the manufacture when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.2.Performance criterion B

After the test, the equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed, after the application of the phenomena below a performance level specified by the manufacture, when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance.

During the test, degradation of performance is allowed. However, no change of operation state or stored data is allowed to persist after the test.

If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.3.Performance criterion C

Loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls by the user in accordance with the manufacture's instructions.

Functions, and/or information stored in non-volatile memory, or protected by a battery backup, shall not be lost.

2. GENERAL INFORMATION

2.1.Description of Device (EUT)

EUT	: Solar Inverter
Model Number	: VMII Plus 5.5KW
Power Supply	Input : AC 90V-280V, 50Hz/60Hz, 38.5A : PV Input : DC 120-450V, Max.100A Output : AC 230V, 50Hz/60Hz, 23.9A

2.2.Description of Test Facility

EMC Lab.

2.3.Statement of the measurement uncertainty

The data and results referenced in this document are true and accurate. The reader is cautioned that there may be errors within the calibration limits of the equipment and facilities. The measurement uncertainty was calculated for all measurements listed in this test report acc. To CISPR 16 – 4 “Specification for radio disturbance and immunity measuring apparatus and methods – Part 4: Uncertainty in EMC Measurements” and is documented in the AOC quality system acc. To DIN EN ISO/IEC 17025. Furthermore, component and process variability of devices similar to that tested may result in additional deviation. The manufacturer has the sole responsibility of continued compliance of the device.

2.4.Measurement Uncertainty

Test Item		Frequency Range	Uncertainty	Note
Radiation Uncertainty	:	30MHz~200MHz	$\pm 2.96\text{dB}$	(1)
		200MHz~1000MHz	$\pm 3.10\text{dB}$	(1)
Conduction Uncertainty	:	150kHz~30MHz	$\pm 1.63\text{dB}$	(1)
Power disturbance	:	30MHz~300MHz	$\pm 1.60\text{dB}$	(1)

(1). This uncertainty represents an expanded uncertainty expressed at approximately the 95% confidence level using a coverage factor of $k=2$.

3. MEASURING DEVICES AND TEST EQUIPMENT

3.1. Conducted Disturbance

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	EMI Test Receiver	ROHDE & SCHWARZ	ESCI	101142	2025/04/25
2	10dB Attenuator	SCHWARZBECK	OSPAM236	9729	2025/04/25
3	Artificial Mains	ROHDE & SCHWARZ	ENV216	101288	2025/04/25
4	EMI Test Software	AUDIX	E3	N/A	2025/04/25

3.2. Disturbance Power

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	EMI Test Receiver	ROHDE & SCHWARZ	ESCI	101142	2025/04/25
2	Absorbing clamp	ROHDE & SCHWARZ	MDS 21	4033	2025/04/25
3	EMI Test Software	AUDIX	E3	N/A	2025/04/25
4	EMI Test Receiver	ROHDE & SCHWARZ	ESPI	101840	2025/04/25

3.3. Radiated Electromagnetic Disturbance

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	EMI Test Receiver	ROHDE & SCHWARZ	ESCI	1011423	2025/04/25
2	Triple-loop Antenna	EVERFINE	LLA-2	11050003	2025/04/25
3	EMI Test Receiver	ROHDE & SCHWARZ	ESPI	101840	2025/04/25
4	EMI Test Software	AUDIX	E3	N/A	2025/04/25

3.4. Radiated Disturbance (Electric Field)

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	3m Semi Anechoic Chamber	SIDT FRANKONIA	SAC-3M	03CH03-HY	2025/04/25
2	EMI Test Receiver	ROHDE & SCHWARZ	ESPI	101840	2025/04/25
3	Log per Antenna	SCHWARZBECK	VULB9163	9163-470	2025/04/25
4	EMI Test Software	AUDIX	E3	N/A	2025/04/25
5	Positioning Controller	MF	MF-7082	/	2025/04/25
6	Horn Antenna	ETS.LINDGREN	3115	00034771	2025/04/25
7	Spectrum Analyzer	Agilent	E4407B	MY41440754	2025/04/25

3.5. Harmonic Current

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Power Analyzer Test System	Voltech	PM6000	20000670053	2025/04/25

3.6. Voltage fluctuation and Flicker

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Power Analyzer Test System	Voltech	PM6000	20000670053	2025/04/25

3.7.Electrostatic Discharge

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	ESD Simulator	KIKUSUI	KC001311	KES4021	2025/04/25

3.8.RF Field Strength Susceptibility

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	SIGNAL GENERATOR	HP	8648A	625U00573	2025/04/25
2	Amplifier	AR	500A100	17034	2025/04/25
3	Amplifier	AR	100W/1000M1	17028	2025/04/25
4	Isotropic Field Monitor	AR	FM2000	16829	2025/04/25
5	Isotropic Field Probe	AR	FP2000	16755	2025/04/25
6	Bi-conic Antenna	EMCO	3108	9507-2534	2025/04/25
7	By-log-periodic Antenna	AR	AT1080	16812	2025/04/25
8	EMS Test Software	ROHDE & SCHWARZ	ESK1	N/A	2025/04/25

3.9.Electrical Fast Transient/Burst

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Electrical fast transient(EFT)generator	3CTEST	EFT-4021	EC0461044	2025/04/25
2	Coupling Clamp	3CTEST	EFTC	EC0441098	2025/04/25

3.10.Surge

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Surge test system	3CTEST	SG5006G	EC5581070	2025/04/25
2	Coupling/decoupling network	3CTEST	SGN-5010G	CS5591033	2025/04/25

3.11.Conducted Susceptibility

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Simulator	EMTEST	CIT-10	A126A1195	2025/04/25
2	CDN	EMTEST	CDN-M2	A2210177	2025/04/25
3	CDN	EMTEST	CDN-M3	A2210177	2025/04/25
4	Attenuator	EMTEST	ATT6	50FP-006-H3B	2025/04/25

3.12.Power Frequency Magnetic Field Susceptibility

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Power frequency mag-field generator System	EVERFINE	EMS61000-8K	906003	2025/04/25

3.13.Voltage Dips


Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Voltage dips and up generator	3CTEST	VDG-1105G	EC0171014	2025/04/25

3.14.Voltage Short Interruptions

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Voltage dips and up generator	3CTEST	VDG-1105G	EC0171014	2025/04/25

4. RADIATED EMISSION MEASUREMENT

4.1. Block Diagram of Test Setup



4.2. Test Standard

EN IEC 61000-6-3:2021 (EN 55032: 2015+A11: 2020)

4.3. Radiated Emission Limits

All emanations from a class B device or system, including any network of conductors and apparatus connected thereto, shall not exceed the level of field strengths specified below:

FREQUENCY (MHz)	DISTANCE (Meters)	FIELD STRENGTHS LIMIT (dB μ V/m)
30 ~ 230	3	40
230 ~ 1000	3	47

- Note: (1) The smaller limit shall apply at the combination point between two frequency bands.
- (2) Distance refers to the distance in meters between the measuring instrument antenna and the closed point of any part of the EUT.

4.4.EUT Configuration on Test

The EN 55022 regulations test method must be used to find the maximum emission during radiated emission measurement.

4.5.Operating Condition of EUT

4.5.1 Turn on the power.

4.5.2 After that, let the EUT work in test mode (ON) and measure it.

4.6.Test Procedure

The EUT is placed on a turntable, which is 0.8 meter high above the ground. The turntable can rotate 360 degrees to determine the position of the maximum emission level. The EUT is set 10 meters away from the receiving antenna, which is mounted on an antenna tower. The antenna can be moved up and down from 1 to 4 meters to find out the maximum emission level. By-log antenna (calibrated by Dipole Antenna) is used as a receiving antenna. Both horizontal and vertical polarization of the antenna is set on test.

The bandwidth of the Receiver is set at 120kHz.

The frequency range from 30MHz to 1000MHz is investigated.


4.7.Test Results

PASS.

The test result please refer to the next page.

Model No.	VMII Plus 5.5KW	Test Mode	ON
Environmental Conditions	24°C / 56% RH	Detector Function	Quasi-peak
Pol	Vertical	Distance	3m
Test Engineer	Liang	Test Date	June 20, 2025

Test Graph




Suspected List

Suspected List									
NO.	Freq. [MHz]	Factor [dB]	Reading [dBμV/m]	Level [dBμV/m]	Limit [dBμV/m]	Margin [dB]	Height [cm]	Angle [°]	Polarity
1	41.9673	-14.19	48.44	34.25	40.00	5.75	100	38	Vertical
2	47.7893	-13.65	49.84	36.19	40.00	3.81	100	43	Vertical
3	53.9346	-14.24	46.97	32.73	40.00	7.27	100	58	Vertical
4	65.9020	-16.64	46.01	29.37	40.00	10.63	100	51	Vertical
5	119.9166	-17.09	47.58	30.49	40.00	9.51	100	169	Vertical
6	155.4952	-18.54	49.33	30.79	40.00	9.21	100	350	Vertical

Model No.	VMII Plus 5.5KW	Test Mode	ON
Environmental Conditions	24°C / 56% RH	Detector Function	Quasi-peak
Pol	Horizontal	Distance	3m
Test Engineer	Liang	Test Date	June 20, 2025

Test Graph




Suspected List

Suspected List									
NO.	Freq. [MHz]	Factor [dB]	Reading [dBμV/m]	Level [dBμV/m]	Limit [dBμV/m]	Margin [dB]	Height [cm]	Angle [°]	Polarity
1	47.7893	-13.65	52.06	38.41	40.00	1.59	100	337	Horizontal
2	53.9346	-14.24	48.31	34.07	40.00	5.93	100	358	Horizontal
3	119.9166	-17.09	51.07	33.98	40.00	6.02	100	22	Horizontal
4	167.7859	-17.50	55.39	37.89	40.00	2.11	100	17	Horizontal
5	187.1924	-16.25	52.19	35.94	40.00	4.06	100	10	Horizontal
6	295.2217	-12.79	48.77	35.98	47.00	11.02	100	25	Horizontal

5. ELECTROSTATIC DISCHARGE TEST

5.1. Block Diagram of Test Setup



5.2. Test Standard

EN IEC 61000-6-1:2019 (EN 61000-4-2: 2009, Severity Level: Air Discharge: Level 3, ± 8 KV Contact Discharge: Level 2, ± 4 KV)

5.3. Severity Levels and Performance Criterion

5.3.1. Severity level

Level	Test Voltage Contact Discharge (KV)	Test Voltage Air Discharge (KV)
1.	± 2	± 2
2.	± 4	± 4
3.	± 6	± 8
4.	± 8	± 15
X	Special	Special

5.3.2. Performance criterion: **B**

5.4. EUT Configuration on Test

The configuration of EUT is listed in Section 3.7.

5.5.Operating Condition of EUT

5.5.1.Setup the EUT as shown in Section 5.1.

5.5.2.Turn on the power of all equipments.

5.5.3.Let the EUT work in test mode (ON) and measure it.

5.6.Test Procedure

5.6.1.Air Discharge

This test is done on a non-conductive surfaces. The round discharge tip of the discharge electrode shall be approached as fast as possible to touch the EUT. After each discharge, the discharge electrode shall be removed from the EUT. The generator is then re-triggered for a new single discharge and repeated 10 times for each pre-selected test point. This procedure shall be repeated until all the air discharge completed.

Because the case of the EUT is metal surface, so it does not need to be tested.

5.6.2.Contact Discharge

All the procedure shall be same as Section 5.6.1. except that the tip of the discharge electrode shall touch the EUT before the discharge switch is operated.

5.6.3.Indirect Discharge For Horizontal Coupling Plane

At least 20 single discharges shall be applied to the horizontal coupling plane, at points on each side of the EUT. The discharge electrode positions vertically at a distance of 0.1m from the EUT and with the discharge electrode touching the coupling plane.

5.6.4.Indirect Discharge For Vertical Coupling Plane

At least 20 single discharge shall be applied to the center of one vertical edge of the coupling plane. The coupling plane, of dimensions 0.5m X 0.5m, is placed parallel to, and positioned at a distance of 0.1m from the EUT. Discharges shall be applied to the coupling plane, with this plane in sufficient different positions that the four faces of the EUT are completely illuminated.

5.7.Test Results

PASS.

Please refer to the following page.

Electrostatic Discharger Test Results

Standard	☐ IEC 61000-4-2 ☒ EN 61000-4-2		
Applicant	Shenzhen SCMK New Energy Co.,Ltd		
EUT	Solar Inverter	Temperature	26℃
M/N	VMII Plus 5.5KW	Humidity	51%
Criterion	B	Pressure	1021mbar
Test Mode	ON	Test Engineer	Liang

Air Discharge

Test Points	Test Levels			Results		
	± 2KV	± 4KV	± 8KV	Pass	Fail	Performance Criterion
Front	☒	☒	☒	☒	☐	☐ A ☒ B
Back	☒	☒	☒	☒	☐	☐ A ☒ B
Left	☒	☒	☒	☒	☐	☐ A ☒ B
Right	☒	☒	☒	☒	☐	☐ A ☒ B
Top	☒	☒	☒	☒	☐	☐ A ☒ B
Bottom	☒	☒	☒	☒	☐	☐ A ☒ B

Contact Discharge

Test Points	Test Levels		Results		
	± 2 KV	±4 KV	Pass	Fail	Performance Criterion
Front	☒	☒	☒	☐	☐ A ☒ B
Back	☒	☒	☒	☐	☐ A ☒ B
Left	☒	☒	☒	☐	☐ A ☒ B
Right	☒	☒	☒	☐	☐ A ☒ B
Top	☒	☒	☒	☐	☐ A ☒ B
Bottom	☒	☒	☒	☐	☐ A ☒ B

Discharge To Horizontal Coupling Plane


Side of EUT	Test Levels		Results		
	± 2 KV	± 4 KV	Pass	Fail	Performance Criterion
Front	☒	☒	☒	☐	☐ A ☒ B
Back	☒	☒	☒	☐	☐ A ☒ B
Left	☒	☒	☒	☐	☐ A ☒ B
Right	☒	☒	☒	☐	☐ A ☒ B

Discharge To Vertical Coupling Plane

Side of EUT	Test Levels		Results		
	± 2 KV	± 4 KV	Pass	Fail	Performance Criterion
Front	☒	☒	☒	☐	☐ A ☒ B
Back	☒	☒	☒	☐	☐ A ☒ B
Left	☒	☒	☒	☐	☐ A ☒ B
Right	☒	☒	☒	☐	☐ A ☒ B

6. RF FIELD STRENGTH SUSCEPTIBILITY TEST

6.1.Block Diagram of Test Setup



6.2.Test Standard

EN IEC 61000-6-1:2019 (EN 61000-4-3:2020 , Severity Level: 2, 3V / m)

6.3.Severity Levels and Performance Criterion

6.3.1.Severity level

Level	Field Strength (V/m)
1	1
2	3
3	10
X	Special

6.3.2.Performance criterion: A

6.4.EUT Configuration on Test

The configuration of EUT are listed in Section 2.1.

6.5.Operating Condition of EUT

6.5.1.Setup the EUT as shown in Section 6.1.

6.5.2.Turn on the power of all equipments.

6.5.3.Let the EUT work in test mode (On) and measure it.

6.6.Test Procedure

The EUT and its simulators are placed on a turn table which is 0.8 meter above ground. EUT is set 3 meter away from the transmitting antenna which is mounted on an antenna tower. Both horizontal and vertical polarization of the antenna are set on test. Each of the four sides of EUT must be faced this transmitting antenna and measured individually. In order to judge the EUT performance, a CCD camera is used to monitor EUT screen. All the scanning conditions are as follows:

Condition of Test	Remarks
-----	-----
1. Fielded Strength	3 V/m (Severity Level 2)
2. Radiated Signal	Unmodulated
3. Scanning Frequency	80 - 1000 MHz
4. Dwell time of radiated	0.0015 decade/s
5. Waiting Time	3 Sec.

6.7.Test Results

PASS.

Please refer to the following page.

RF Field Strength Susceptibility Test Results

Standard	☐ IEC 61000-4-3 ☒ EN 61000-4-3		
Applicant	Shenzhen SCMK New Energy Co.,Ltd		
EUT	Solar Inverter	Temperature	26℃
M/N	VMII Plus 5.5KW	Humidity	51%
Field Strength	3 V/m	Criterion	A
Test Mode	ON	Test Engineer	Liang
Frequency Range	80 MHz to 1000 MHz		
Modulation	☐ None ☐ Pulse ☒ AM 1KHz 80%		
Steps	1%		

	Horizontal	Vertical
Front	PASS	PASS
Right	PASS	PASS
Rear	PASS	PASS
Left	PASS	PASS


Test Equipment:

1. Signal Generator: 2031 (MARCONI)
2. Power Amplifier: 500A100 & 100W/1000M1 (A&R)
3. Power Antenna: 3108 (EMCO) & AT1080 (A&R)
4. Field Monitor: FM2000 (A&R)

Note:

7. MAGNETIC FIELD IMMUNITY TEST

7.1. Block Diagram of Test Setup



7.2. Test Standard

EN IEC 61000-6-1:2019 (EN 61000-4-8: 2010, Severity Level 2: 3A/m)

7.3. Severity Levels and Performance Criterion

7.3.1. Severity level

Level	Magnetic Field Strength (A/m)
1.	1
2.	3
3.	10
4.	30
5.	100
X	Special

7.3.2. Performance criterion: A

7.4. EUT Configuration on Test

The configuration of EUT are listed in Section 3.12.

7.5.Operating Condition of EUT

7.5.1.Setup the EUT as shown in Section 7.1.

7.5.2.Turn on the power of all equipments.

7.5.3.Let the EUT work in test mode (On) and measure it.

7.6.Test Procedure

7.6.1.Set up the EUT system as shown on Section 7.1.

7.6.2.The Induction coil is set up in horizontal or vertical.

7.6.3.Let the EUT work in test mode and measure it.

7.7.Test Results

PASS.

Please refer to the following page.

Magnetic Field Immunity Test Result

Standard	☐ IEC 61000-4-8 ☒ EN 61000-4-8		
Applicant	Shenzhen SCMK New Energy Co.,Ltd		
EUT	Solar Inverter	Temperature	26℃
M/N	VMII Plus 5.5KW	Humidity	51%
Test Mode	Normal	Criterion	A
Test Engineer	Liang	Test Date	June 20, 2025

Test Level (A/M)	Testing Duration	Coil Orientation	Criterion	Result
3	5 mins	X	A	PASS
3	5 mins	Y	A	PASS
3	5 mins	Z	A	PASS

Note:

8. PHOTOGRAPH

8.1 Photo of Radiated Measurement




Fig.1

9. EXTERNAL AND INTERNAL PHOTOS OF THE EUT




Fig. 1



Fig.2



Fig.3



Fig.4

-----THE END OF REPORT-----