

HEALTH TEST REPORT

For

ELECTRO MEGALUX


Electric Storage Water Heater

Test Model No.: ML-FVDS1-80L


Additional Model No.: ML-FVDS1-30L, ML-FVDS1-50L, ML-FVDS1-100L,
ML-FVDS1-40L, ML-FVDS1-60L

Prepared for	:	ELECTRO MEGALUX
Address	:	AV MY RACHID RS HADAIK VALFLEURIIM.4 RDC N°8, TANGERMOROCCO
Prepared by	:	Shenzhen AOCE Electronic Technology Service Co., Ltd
Address	:	Room 202, 2nd Floor, No.12th Building of Xinhe Tongfuyu Industrial Park, Fuhai Street, Baoan District, Shenzhen, Guangdong, China
Tel	:	(86)755-85277785
Fax	:	(86)755-23705230
Web	:	Http://www.aoc-cert.com
Mail	:	postmaster@aoc-cert.com
Date of receipt of test sample	:	July 18, 2025
Number of tested samples	:	1
Serial number	:	Prototype
Date of Test	:	July 18, 2025~July 29, 2025
Date of Report	:	July 29, 2025

HEALTH TEST REPORT EN IEC 62311: 2020 Assessment of electronic and electrical equipment related to human exposure restrictions for electromagnetic fields (0 Hz - 300 GHz)	
Report Reference No.	: AOC250729106E
Date of Issue	: July 29, 2025
Testing Laboratory Name	: Shenzhen AOCE Electronic Technology Service Co.,
Address	: Room 202, 2nd Floor, No.12th Building of Xinhe Tongfuyu Industrial Park, Fuhai Street, Baoan District, Shenzhen, Guangdong, China
Testing Location/ Procedure	: Full application of Harmonised standards <input checked="" type="checkbox"/> : Partial application of Harmonised standards <input type="checkbox"/> : Other standard testing method <input type="checkbox"/>
Applicant's Name	: ELECTRO MEGALUX
Address	: AV MY RACHID RS HADAIK VALFLEURIIM.4 RDC N'8, TANGERMOROCCO
Test Specification Standard..... : EN IEC 62311: 2020 Test Report Form No. : AOCEMC-1.0 TRF Originator..... : Shenzhen AOCE Electronic Technology Service Co., Ltd Master TRF : Dated 2017-06	
Shenzhen AOCE Electronic Technology Service Co., Ltd All rights reserved. This publication may be reproduced in whole or in part for non-commercial purposes as long as the Shenzhen AOCE Electronic Technology Service Co., Ltd is acknowledged as copyright owner and source of the material. Shenzhen AOCE Electronic Technology Service Co., Ltd takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
Test Item Description	: Electric Storage Water Heater
Trade Mark	: Megalife
Model/ Type reference	: ML-FVDS1-80L
Ratings	: AC 220-240V, 50/60Hz, Max.2000W
Result	: Positive

Compiled by:


Johnson Wang/ Administrators

Supervised by:


Joey Liu/ Technique principal

Approved by:


Murry Yu/ Manager

RADIO -- TEST REPORT

Test Report No. : AOC250729106E	<u>July 29, 2025</u> Date of issue
--	---------------------------------------

Type / Model.....	: ML-FVDS1-80L
EUT.....	: Electric Storage Water Heater
.....	
Applicant.....	: ELECTRO MEGALUX
....	
Address.....	: AV MY RACHID RS HADAIK VALFLEURIIM.4 RDC N'8,
....	TANGERMOROCCO
Telephone.....	: /
....	
Fax.....	: /
....	
Manufacturer.....	: Guangdong Well-born Electric Appliance Co., Ltd.
...	
Address.....	: No. 15 HuaTian Road, South First Road, Ronggui,
....	Shunde, Foshan, Guangdong, China
Telephone.....	: /
....	
Fax.....	: /
....	
Factory.....	: Guangdong Well-born Electric Appliance Co., Ltd.
.....	
Address.....	: No. 15 HuaTian Road, South First Road, Ronggui,
....	Shunde, Foshan, Guangdong, China
Telephone.....	: /
....	
Fax.....	: /
....	

Test Result	Positive
--------------------	-----------------

The test report merely corresponds to the test sample.
It is not permitted to copy extracts of these test result without the written permission of the test laboratory.

1. GENERAL INFORMATION

1.1 Product Description for Equipment Under Test (EUT)

EUT : Electric Storage Water Heater
Test Model : ML-FVDS1-80L
Model No. List ML-FVDS1-80L, ML-FVDS1-30L, ML-FVDS1-50L,
ML-FVDS1-100L, ML-FVDS1-40L, ML-FVDS1-60L
Hardware Version : V1.1
Software Version : V1.1

Bluetooth :
Frequency Range : 2402MHz ~ 2480MHz
Channel Number : 40 channels

Channel Spacing : 2MHz
Modulation Type : GFSK
Bluetooth Version : V5.2
Antenna Type : PIFA Antenna
Antenna Gain : 1.2 dBi

1.2. Objective

According to its specifications, the EUT must comply with the requirements of the following standards:

EN IEC 62311: 2020 –Assessment of the compliance of low power electronic and electrical equipment with the basic restrictions related to human exposure to electromagnetic fields (10 MHz to 300 GHz)

1.3. Related Submittal(s)/Grant(s)

No Related Submittals.

1.4. Test Methodology

All measurements contained in this report were conducted with EN 62479:2010.

1.5. Support equipment List

Manufacturer	Description	Model	Serial Number	Certificate
/	/	/	/	/

2. HUMAN EXPOSURE TO THE ELECTROMAGNETIC FIELDS

2.1 Basic Restrictions Reference levels

Council Recommendation 1999/519/EC Annex III

Basic restrictions for electric, magnetic and electromagnetic fields (0Hz to 300GHz)

Frequency range	Magnetic flux density (mT)	Current density (Ma/m ²) (rms)	Whole body average SAR (W/kg)	Localised SAR (head and trunk) (W/kg)	Localised SAR (limbs) (W/kg)	Power density (W/m ²)
0Hz	40	-	-	-	-	-
>0-1Hz	-	8	-	-	-	-
1-4Hz	-	8/f	-	-	-	-
4-1000Hz	-	2	-	-	-	-
1000Hz-100kHz	-	f/500	-	-	-	-
100kHz-10MHz	-	f/500	0.08	2	4	-
10MHz-10GHz	-	-	0.08	2	4	-
10-300GHz	-	-	-	-	-	10

Note:

1. f is the frequency in Hz.
2. The basic restriction on the current density is intended to protect against acute exposure effects on central nervous system tissues in the head and trunk of the body and includes a safety factor. The basic restrictions for ELF fields are based on established adverse effects on the central nervous system. Such acute effects are essentially instantaneous and there is no scientific justification to modify the basic restrictions for exposure of short duration. However, since the basic restriction refers to adverse effects on the central nervous system, this basic restriction may permit higher current densities in body tissues other than the central nervous system under the same exposure conditions.
3. Because of electrical inhomogeneity of the body, current densities should be averaged over a cross section of 1cm² perpendicular to the current direction.
4. For frequencies up to 100 kHz, peak current density values can be obtained by multiplying the rms value by $\sqrt{2}$ (=1.414). For pulses of duration t_p the equivalent frequency to apply in the basic restrictions should be calculated as $f=1/(2t_p)$
5. For frequencies up to 100kHz and for pulsed magnetic fields, the maximum current density associated with the pulses can be calculated from the rise/fall times and the maximum rate of change of magnetic flux density. The induced current density can then be compared with the appropriate basic restriction.
6. All SAR values are to be averaged over any six-minute period.
7. Localised SAR averaging mass is any 10g of contiguous tissue; the maximum SAR so obtained should be the value used for the estimation of exposure. These 10g of tissue are intended to be a mass of contiguous tissue with nearly homogeneous electrical properties. In specifying a contiguous mass of tissue, it is recognised that this concept can be used in computational dosimetry but may present difficulties for direct physical measurements. A simple geometry such as cubic tissue mass can be used provided that the calculated dosimetric quantities have conservation values relative to the exposure guidelines.

8. For pulses of duration t_p the equivalent frequency to apply in the basic restrictions should be calculated as $f = 1/(2t_p)$. Additionally, for pulsed exposures, in the frequency range 0,3 to 10GHz and for localised exposure of the head, in order to limit and avoid auditory effects caused by thermoelastic expansion, an additional basic restriction is recommended. This is that SA should not exceed 2mJ kg⁻¹ averaged over 10g of tissue.

2.2 Reference Levels

Council Recommendation 1999/519/EC Annex III

Reference levels for electric, magnetic and electromagnetic fields (0Hz to 300GHz)

Frequency range	E-field strength (V/m)	H-field strength (A/m)	B-field (μT)	Equivalent plane wave power density Seq (W/m ²)
0-1Hz	-	$3,2 \times 10^4$	4×10^4	-
1-8Hz	1000	$3,2 \times 10^4 / f^2$	$4 \times 10^4 / f^2$	-
8-25Hz	1000	$4000/f$	$5000/f$	-
0.025Hz-0,8kHz	$250/f$	$4/f$	$5/f_{6,25}$	-
0,8-3kHz	$250/f$	5	6,25	-
3-150kHz	87	5	6,25	-
0,15-1MHz	87	$0.73/f$	$0.92/f$	-
1-10MHz	$87/f^{1/2}$	$0.73/f$	$0.92/f$	-
10-400MHz	28	0.073	0,092	2
400-2000MHz	$1,375 f^{1/2}$	$0,0037 f^{1/2}$	$0,0046 f^{1/2}$	$f/200$
2-300GHz	61	0,16	0,20	10

Note:

1. As indicated in the frequency range column.
2. For frequencies between 100kHz and 10GHz, Seq, E2, H2 and B2 are to be averaged over any six-minute period.
3. For frequencies exceeding 10GHz, Seq, E2, H2 and B2 are to be averaged over any 68/.1.05-minute period (.in GHz).
4. No E-field value is provided for frequencies <1Hz, which are effectively static electric fields. For most people the annoying perception of surface electric charges will not occur at field strengths less than 20kV/m. Spark discharges causing stress or annoyance should be avoided.

2.3 Test Results

$$\text{Exposure evaluation} \quad E = \frac{\sqrt{30 \times G \times TP}}{D}$$

1. Minimum distance in meter (D) (from transmitting structure to the human body)
2. Antenna gain (G)
3. Max average output power in Watt (TP)=EIRP-Antenna gain

significant lower than the 61V/m as required in Annex III table 2 of EC Council Recommendation (1999/519/EC). This proves that the unit complies with the EN 62311 for RF exposure requirement.

-----THE END OF REPORT-----