

EMC TEST REPORT
For
DONGGUAN KAPEGO COMPANY LIMITED
Recessed Swimming Pool Light
Model No.: B4FE1819 D

Additional Model No.: B4A0119 D, B4SA0320, B4SB0320, B4TD0620 D, B4TC0620 D, B4XE0419 D, B4YE0620 D, B4ZE1219 D, B4SA0619, B4TA1219, B4XE0419, B4YE0620, B4ZE1219, B4FE1819, B4QA0619

Prepared for : DONGGUAN KAPEGO COMPANY LIMITED
Address : No.2 Chang Le Dong Road, YuNing Industrial Zone Heng Li Town, Dongguan, Guangdong, China 523478

Prepared by : Shenzhen AOCE Electronic Technology Service Co., Ltd.
Address : Room 202, 2nd Floor, No.12th Building of Xinhe Tongfuyu Industrial Park, Fuhai Street, Baoan District, Shenzhen, Guangdong, China

Tel : (+86)755-85277785
Fax : (+86)755-23705230
Web : www.aoc-cert.com
Mail : postmaster@aoc-cert.com

Date of receipt of test sample : October 24, 2025
Number of tested samples : 1
Serial number : Prototype
Date of Test : October 24, 2025 - October 31, 2025
Date of Report : October 31, 2025



EMC TEST REPORT
EN 55015: 2019+A11: 2020

Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment

EN IEC 61547: 2023

Equipment for general lighting purposes - EMC immunity requirements

Report Reference No.: AOC251031105E

Date Of Issue: October 31, 2025

Testing Laboratory Name.....: Shenzhen AOCE Electronic Technology Service Co., Ltd.

Address: Room 202, 2nd Floor, No.12th Building of Xinhe Tongfuyu Industrial Park, Fuhai Street, Baoan District, Shenzhen, Guangdong, China

Testing Location/ Procedure: Full application of Harmonised standards ☒
 Partial application of Harmonised standards ☐
 Other standard testing method ☐

Applicant's Name: DONGGUAN KAPEGO COMPANY LIMITED

Address: No.2 Chang Le Dong Road, YuNing Industrial Zone Heng Li Town, Dongguan, Guangdong, China 523478

Test Specification:

Standard: EN 55015:2019+A11:2020
 EN IEC 61000-3-2:2019+A1:2021+A2:2024
 EN 61000-3-3:2013+A1:2019+A2:2021+AC:2022
 EN IEC 61547: 2023

Test Report Form No.....: AOCEMC-1.0

TRF Originator: Shenzhen AOCE Electronic Technology Service Co., Ltd.

Master TRF: Dated 2011-03

Shenzhen AOCE Electronic Technology Service Co., Ltd. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the Shenzhen AOCE Electronic Technology Service Co., Ltd. is acknowledged as copyright owner and source of the material. Shenzhen AOCE Electronic Technology Service Co., Ltd. takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

Test Item Description.....: Recessed Swimming Pool Light

Trade Mark: KAPEGO

Model/ Type Reference: B4FE1819 D

Ratings: DC 24V, 60W, Class III, IP68

Result: Positive

Compiled by:

David Liu

Supervised by:

Kevin Huang

Approved by:

Jackson Fang

David Liu/ File administrators

Kevin Huang/ Technique principal

Jackson Fang/ Manager

EMC -- TEST REPORT

Test Report No. : AOC251031105EOctober 31, 2025

Date of issue

Type / Model..... : Recessed Swimming Pool Light

EUT..... : B4FE1819 D

Applicant..... : DONGGUAN KAPEGO COMPANY LIMITEDAddress..... : No.2 Chang Le Dong Road, YuNing Industrial Zone Heng Li
Town, Dongguan, Guangdong, China 523478

Telephone..... : /

Fax..... : /

Manufacturer..... : DONGGUAN KAPEGO COMPANY LIMITEDAddress..... : No.2 Chang Le Dong Road, YuNing Industrial Zone Heng Li
Town, Dongguan, Guangdong, China 523478

Telephone..... : /

Fax..... : /

Factory..... : DONGGUAN KAPEGO COMPANY LIMITEDAddress..... : No.2 Chang Le Dong Road, YuNing Industrial Zone Heng Li
Town, Dongguan, Guangdong, China 523478

Telephone..... : /

Fax..... : /

Test Result according to the standards on page 6:**Pass**

The test report merely corresponds to the test sample.

It is not permitted to copy extracts of these test result without the written permission of the test laboratory.

TABLE OF CONTENTS

Test Report Description	Page
1. SUMMARY OF STANDARDS AND RESULTS	6
1.1.Description of Standards and Results	6
1.2.Description of Performance Criteria.....	7
2. GENERAL INFORMATION	8
2.1.Description of Device (EUT).....	8
2.2.Description of Test Facility	8
2.3.Statement of the measurement uncertainty	8
2.4.Measurement Uncertainty	8
3. MEASURING DEVICES AND TEST EQUIPMENT	9
3.1.Conducted Disturbance	9
3.2.Disturbance Power	9
3.3.Radiated Electromagnetic Disturbance.....	9
3.4.Radiated Disturbance (Electric Field)	9
3.5.Harmonic Current.....	9
3.6.Voltage fluctuation and Flicker	9
3.7.Electrostatic Discharge	9
3.8.RF Field Strength Susceptibility.....	10
3.9.Electrical Fast Transient/Burst.....	10
3.10.Surge.....	10
3.11.Conducted Susceptibility	10
3.12.Power Frequency Magnetic Field Susceptibility	10
3.13.Voltage Dips.....	10
3.14.Voltage Short Interruptions	10
4. MAGNETIC FIELD EMISSION MEASUREMENT	11
4.1.Block Diagram of Test Setup.....	11
4.2.Magnetic Field Emission Measurement Standard and Limits.....	11
4.3.EUT Configuration on Test	11
4.4.Operating Condition of EUT	11
4.5.Test Procedure.....	12
4.6.Test Results	12
5. RADIATED EMISSION MEASUREMENT	13
5.1.Block Diagram of Test Setup.....	13
5.2.Test Standard.....	13
5.3.Radiated Emission Limits	13
5.4.EUT Configuration on Test	14
5.5.Operating Condition of EUT	14
5.6.Test Procedure.....	14

5.7.Test Results	14
6. ELECTROSTATIC DISCHARGE TEST	16
6.1.Block Diagram of Test Setup.....	16
6.2.Test Standard.....	16
6.3.Severity Levels and Performance Criterion.....	16
6.4.EUT Configuration on Test	16
6.5.Operating Condition of EUT	17
6.6.Test Procedure.....	17
6.7.Test Results	17
7. RF FIELD STRENGTH SUSCEPTIBILITY TEST	19
7.1.Block Diagram of Test Setup.....	19
7.2.Test Standard.....	19
7.3.Severity Levels and Performance Criterion.....	19
7.4.EUT Configuration on Test	20
7.5.Operating Condition of EUT	20
7.6.Test Procedure.....	20
7.7.Test Results	20
8. MAGNETIC FIELD IMMUNITY TEST	22
8.1.Block Diagram of Test Setup.....	22
8.2.Test Standard.....	22
8.3.Severity Levels and Performance Criterion.....	22
8.4.EUT Configuration on Test	22
8.5.Operating Condition of EUT	23
8.6.Test Procedure.....	23
8.7.Test Results	23
9. PHOTOGRAPH	25
9.1.Photo of Radiated Measurement.....	25
10. EXTERNAL AND INTERNAL PHOTOS OF THE EUT.....	26

1. SUMMARY OF STANDARDS AND RESULTS

1.1. Description of Standards and Results

The EUT have been tested according to the applicable standards as referenced below.

EMISSION (EN 55015: 2019+A11: 2020)			
Description of Test Item	Standard	Limits	Results
Conducted disturbance at mains terminals	EN 55015: 2019+A11: 2020	-----	N/A
Magnetic field emission	EN 55015: 2019+A11: 2020	-----	PASS
Radiated disturbance	EN 55015: 2019+A11: 2020	-----	PASS
Harmonic current emissions	EN IEC 61000-3-2: 2019+A1:2021+A2:2024	Class C	N/A
Voltage fluctuations & flicker	EN 61000-3-3:2013+A1:2019+A2:2021+AC:2022	-----	N/A
IMMUNITY (EN IEC 61547: 2023)			
Description of Test Item	Basic Standard	Performance Criteria	Results
Electrostatic discharge (ESD)	EN 61000-4-2: 2009	B	PASS
Radio-frequency, Continuous radiated disturbance	EN 61000-4-3: 2020	A	PASS
Electrical fast transient (EFT)	EN 61000-4-4: 2012	B	N/A
Surge (Input a.c. power ports)	EN 61000-4-5: 2014+A1: 2017	B	N/A
Radio-frequency, Continuous conducted disturbance	EN 61000-4-6: 2014+AC: 2015	A	N/A
Power frequency magnetic field	EN 61000-4-8: 2010	A	PASS
Voltage dips, 30% reduction	EN 61000-4-11: 2020	C	N/A
Voltage interruptions		B	N/A
N/A is an abbreviation for Not Applicable.			

1.2. Description of Performance Criteria

General Performance Criteria

Examples of functions defined by the manufacturer to be evaluated during testing include, but are not limited to, the following:

- essential operational modes and states;
- tests of all peripheral access (hard disks, floppy disks, printers, keyboard, mouse, etc.);
- quality of software execution;
- quality of data display and transmission;
- quality of speech transmission.

1.2.1. Performance criterion A

The equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed below a performance level specified by the manufacture when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.2. Performance criterion B

After the test, the equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed, after the application of the phenomena below a performance level specified by the manufacture, when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance.

During the test, degradation of performance is allowed. However, no change of operation state or stored data is allowed to persist after the test.

If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.3. Performance criterion C

Loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls by the user in accordance with the manufacture's instructions.

Functions, and/or information stored in non-volatile memory, or protected by a battery backup, shall not be lost.

2. GENERAL INFORMATION

2.1. Description of Device (EUT)

EUT	: Recessed Swimming Pool Light
Model Number	: B4FE1819 D
Power Supply	: DC 24V, 60W, Class III, IP68

2.2. Description of Test Facility

EMC Lab.

2.3. Statement of the measurement uncertainty

The data and results referenced in this document are true and accurate. The reader is cautioned that there may be errors within the calibration limits of the equipment and facilities. The measurement uncertainty was calculated for all measurements listed in this test report acc. To CISPR 16 – 4 “Specification for radio disturbance and immunity measuring apparatus and methods – Part 4: Uncertainty in EMC Measurements” and is documented in the AOC quality system acc. To DIN EN ISO/IEC 17025. Furthermore, component and process variability of devices similar to that tested may result in additional deviation. The manufacturer has the sole responsibility of continued compliance of the device.

2.4. Measurement Uncertainty

Test Item		Frequency Range	Uncertainty	Note
Radiation Uncertainty	:	30MHz~200MHz	±2.96dB	(1)
		200MHz~1000MHz	±3.10dB	(1)
Conduction Uncertainty	:	150kHz~30MHz	±1.63dB	(1)
Power disturbance	:	30MHz~300MHz	±1.60dB	(1)

(1). This uncertainty represents an expanded uncertainty expressed at approximately the 95% confidence level using a coverage factor of k=2.

3. MEASURING DEVICES AND TEST EQUIPMENT

3.1. Conducted Disturbance

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	EMI Test Receiver	ROHDE & SCHWARZ	ESCI	101142	2025/04/13
2	10dB Attenuator	SCHWARZBECK	OSPAM236	9729	2025/04/13
3	Artificial Mains	ROHDE & SCHWARZ	ENV216	101288	2025/04/13
4	EMI Test Software	AUDIX	E3	N/A	2025/04/13

3.2. Disturbance Power

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	EMI Test Receiver	ROHDE & SCHWARZ	ESCI	101142	2025/04/13
2	Absorbing clamp	ROHDE & SCHWARZ	MDS 21	4033	2025/04/13
3	EMI Test Software	AUDIX	E3	N/A	2025/04/13

3.3. Radiated Electromagnetic Disturbance

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	EMI Test Receiver	ROHDE & SCHWARZ	ESCI	1011423	2025/04/13
2	Triple-loop Antenna	EVERFINE	LLA-2	11050003	2025/04/13
3	EMI Test Receiver	ROHDE & SCHWARZ	ESPI	101840	2025/04/13
4	EMI Test Software	AUDIX	E3	N/A	2025/04/13

3.4. Radiated Disturbance (Electric Field)

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	3m Semi Anechoic Chamber	SIDT FRANKONIA	SAC-3M	03CH03-HY	2025/04/13
2	EMI Test Receiver	ROHDE & SCHWARZ	ESPI	101840	2025/04/13
3	Log per Antenna	SCHWARZBECK	VULB9163	9163-470	2025/04/13
4	EMI Test Software	AUDIX	E3	N/A	2025/04/13
5	Positioning Controller	MF	MF-7082	/	2025/04/13

3.5. Harmonic Current

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Power Analyzer Test System	Voltech	PM6000	20000670053	2025/04/13

3.6. Voltage fluctuation and Flicker

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Power Analyzer Test System	Voltech	PM6000	20000670053	2025/04/13

3.7. Electrostatic Discharge

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	ESD Simulator	KIKUSUI	KC001311	KES4021	2025/04/13

3.8.RF Field Strength Susceptibility

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	SIGNAL GENERATOR	HP	8648A	625U00573	2025/04/13
2	Amplifier	AR	500A100	17034	2025/04/13
3	Amplifier	AR	100W/1000M1	17028	2025/04/13
4	Isotropic Field Monitor	AR	FM2000	16829	2025/04/13
5	Isotropic Field Probe	AR	FP2000	16755	2025/04/13
6	Bi-conic Antenna	EMCO	3108	9507-2534	2025/04/13
7	By-log-periodic Antenna	AR	AT1080	16812	2025/04/13
8	EMS Test Software	ROHDE & SCHWARZ	ESK1	N/A	2025/04/13

3.9.Electrical Fast Transient/Burst

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Electrical fast transient(EFT)generator	3CTEST	EFT-4021	EC0461044	2025/04/13
2	Coupling Clamp	3CTEST	EFTC	EC0441098	2025/04/13

3.10.Surge

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Surge test system	3CTEST	SG5006G	EC5581070	2025/04/13
2	Coupling/decoupling network	3CTEST	SGN-5010G	CS5591033	2025/04/13

3.11.Conducted Susceptibility

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Simulator	EMTEST	CIT-10	A126A1195	2025/04/13
2	CDN	EMTEST	CDN-M2	A2210177	2025/04/13
3	CDN	EMTEST	CDN-M3	A2210177	2025/04/13
4	Attenuator	EMTEST	ATT6	50FP-006-H3B	2025/04/13

3.12.Power Frequency Magnetic Field Susceptibility

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Power frequency mag-field generator System	EVERFINE	EMS61000-8K	906003	2025/04/13

3.13.Voltage Dips


Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Voltage dips and up generator	3CTEST	VDG-1105G	EC0171014	2025/04/13

3.14.Voltage Short Interruptions

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Voltage dips and up generator	3CTEST	VDG-1105G	EC0171014	2025/04/13

4. MAGNETIC FIELD EMISSION MEASUREMENT

4.1. Block Diagram of Test Setup



4.2. Magnetic Field Emission Measurement Standard and Limits

4.2.1. Test Standard

EN 55015: 2019+A11: 2020

4.2.2. Test Limits

Frequency	Limits for loop diameter (dB μ A)
	2m
9kHz ~ 70kHz	88
70kHz ~ 150kHz	88 ~ 58*
150kHz ~ 3.0MHz	58 ~ 22*
3.0MHz ~ 30MHz	22

1. At the transition frequency the lower limit applies.
2. * decreasing linearly with logarithm of the frequency.

4.3. EUT Configuration on Test

The configuration of the EUT is same as Section 3.3.

4.4. Operating Condition of EUT

- 4.4.1. Setup the EUT as shown in Section 4.1.
- 4.4.2. Turn on the power of all equipments.
- 4.4.3. Let the EUT work in test mode (On) and measure it.

4.5. Test Procedure

The EUT is placed on a wood table in the center of a loop antenna. The induced current in the loop antenna is measured by means of a current probe and the test receiver. Three field components are checked by means of a coaxial switch.

The frequency range from 9kHz to 30MHz is investigated. The receiver is measured with the quasi-peak detector. For frequency band 9kHz to 150kHz, the bandwidth of the field strength meter is set at 200Hz. For frequency band 150kHz to 30MHz, the bandwidth is set at 9kHz.

All the test results are listed in Section 4.6.


4.6. Test Results

PASS.

The frequency range from 9kHz to 30MHz is investigated.

5. RADIATED EMISSION MEASUREMENT

5.1. Block Diagram of Test Setup



5.2. Test Standard

EN 55015: 2019+A11: 2020

5.3. Radiated Emission Limits

All emanations from a class B device or system, including any network of conductors and apparatus connected thereto, shall not exceed the level of field strengths specified below:

FREQUENCY (MHz)	DISTANCE (Meters)	FIELD STRENGTHS LIMIT (dB μ V/m)
30 ~ 230	3	40
230 ~ 300	3	47

- Note: (1) The smaller limit shall apply at the combination point between two frequency bands.
- (2) Distance refers to the distance in meters between the measuring instrument antenna and the closed point of any part of the EUT.

5.4.EUT Configuration on Test

The EN 55015 regulations test method must be used to find the maximum emission during radiated emission measurement.

5.5.Operating Condition of EUT

5.5.1 Turn on the power.

5.5.2 After that, let the EUT work in test mode (ON) and measure it.

5.6.Test Procedure

The EUT is placed on a turntable, which is 0.8 meter high above the ground. The turntable can rotate 360 degrees to determine the position of the maximum emission level. The EUT is set 10 meters away from the receiving antenna, which is mounted on an antenna tower. The antenna can be moved up and down from 1 to 4 meters to find out the maximum emission level. By-log antenna (calibrated by Dipole Antenna) is used as a receiving antenna. Both horizontal and vertical polarization of the antenna is set on test.

The bandwidth of the Receiver is set at 120kHz.


The frequency range from 30MHz to 300MHz is investigated.

5.7.Test Results

PASS.


The test result please refer to the next page.

Model No.	B4FE1819 D	Test Mode	ON
Environmental Conditions	24°C/ 56% RH	Detector Function	Quasi-peak
Pol	Vertical	Distance	3m
Test Engineer	Gao		




Suspected List									
NO.	Freq. [MHz]	Factor [dB]	Reading [dBμV/m]	Level [dBμV/m]	Limit [dBμV/m]	Margin [dB]	Height [cm]	Angle [°]	Polarity
1	57.187187	-17.96	53.27	35.31	40.00	4.69	100	351	Vertical
2	103.79379	-20.94	45.82	24.88	40.00	15.12	100	23	Vertical
3	132.92292	-18.28	49.38	31.10	40.00	8.90	100	195	Vertical
4	164.96496	-17.34	45.64	28.30	40.00	11.70	100	116	Vertical
5	354.30430	-15.99	45.40	29.41	47.00	17.59	100	217	Vertical
6	441.69169	-14.05	52.88	38.83	47.00	8.17	100	337	Vertical

Model No.	B4FE1819 D	Test Mode	ON
Environmental Conditions	24°C/ 56% RH	Detector Function	Quasi-peak
Pol	Horizontal	Distance	3m
Test Engineer	Gao		



Suspected List									
NO.	Freq. [MHz]	Factor [dB]	Reading [dBμV/m]	Level [dBμV/m]	Limit [dBμV/m]	Margin [dB]	Height [cm]	Angle [°]	Polarity
1	58.158158	-18.07	40.25	22.18	40.00	17.82	100	172	Horizontal
2	122.24224	-18.89	48.29	29.40	40.00	10.60	100	245	Horizontal
3	154.28428	-16.91	39.00	22.09	40.00	17.91	100	112	Horizontal
4	214.48448	-20.93	42.46	21.53	40.00	18.47	100	108	Horizontal
5	403.82382	-14.93	49.02	34.09	47.00	12.91	100	173	Horizontal
6	460.14014	-13.88	45.15	31.27	47.00	15.73	100	123	Horizontal

6.1. Block Diagram of Test Setup



6.5. Operating Condition of EUT

- 6.5.1. Setup the EUT as shown in Section 6.1.
- 6.5.2. Turn on the power of all equipments.
- 6.5.3. Let the EUT work in test mode (ON) and measure it.

6.6. Test Procedure

6.6.1. Air Discharge

This test is done on a non-conductive surfaces. The round discharge tip of the discharge electrode shall be approached as fast as possible to touch the EUT. After each discharge, the discharge electrode shall be removed from the EUT. The generator is then re-triggered for a new single discharge and repeated 10 times for each pre-selected test point. This procedure shall be repeated until all the air discharge completed.

Because the case of the EUT is metal surface, so it does not need to be tested.

6.6.2. Contact Discharge

All the procedure shall be same as Section 6.6.1. except that the tip of the discharge electrode shall touch the EUT before the discharge switch is operated.

6.6.3. Indirect Discharge For Horizontal Coupling Plane

At least 20 single discharges shall be applied to the horizontal coupling plane, at points on each side of the EUT. The discharge electrode positions vertically at a distance of 0.1m from the EUT and with the discharge electrode touching the coupling plane.

6.6.4. Indirect Discharge For Vertical Coupling Plane

At least 20 single discharge shall be applied to the center of one vertical edge of the coupling plane. The coupling plane, of dimensions 0.5m X 0.5m, is placed parallel to, and positioned at a distance of 0.1m from the EUT. Discharges shall be applied to the coupling plane, with this plane in sufficient different positions that the four faces of the EUT are completely illuminated.

6.7. Test Results

PASS.

Please refer to the following page.

Electrostatic Discharger Test Results

Standard	☐ IEC 61000-4-2 ☒ EN 61000-4-2		
Applicant	Sonway Co., Limited		
EUT	Recessed Swimming Pool Light	Temperature	26℃
M/N	B4FE1819 D	Humidity	51%
Criterion	B	Pressure	1021mbar
Test Mode	ON	Test Engineer	Gao

Air Discharge

Test Points	Test Levels			Results		
	± 2KV	± 4KV	± 8KV	Pass	Fail	Performance Criterion
Front	☒	☒	☒	☒	☐	☐ A ☒ B
Back	☒	☒	☒	☒	☐	☐ A ☒ B
Left	☒	☒	☒	☒	☐	☐ A ☒ B
Right	☒	☒	☒	☒	☐	☐ A ☒ B
Top	☒	☒	☒	☒	☐	☐ A ☒ B
Bottom	☒	☒	☒	☒	☐	☐ A ☒ B

Contact Discharge

Test Points	Test Levels		Results		
	± 2 KV	±4 KV	Pass	Fail	Performance Criterion
Front	☒	☒	☒	☐	☐ A ☒ B
Back	☒	☒	☒	☐	☐ A ☒ B
Left	☒	☒	☒	☐	☐ A ☒ B
Right	☒	☒	☒	☐	☐ A ☒ B
Top	☒	☒	☒	☐	☐ A ☒ B
Bottom	☒	☒	☒	☐	☐ A ☒ B

Discharge To Horizontal Coupling Plane


Side of EUT	Test Levels		Results		
	± 2 KV	± 4 KV	Pass	Fail	Performance Criterion
Front	☒	☒	☒	☐	☐ A ☒ B
Back	☒	☒	☒	☐	☐ A ☒ B
Left	☒	☒	☒	☐	☐ A ☒ B
Right	☒	☒	☒	☐	☐ A ☒ B

Discharge To Vertical Coupling Plane

Side of EUT	Test Levels		Results		
	± 2 KV	± 4 KV	Pass	Fail	Performance Criterion
Front	☒	☒	☒	☐	☐ A ☒ B
Back	☒	☒	☒	☐	☐ A ☒ B
Left	☒	☒	☒	☐	☐ A ☒ B
Right	☒	☒	☒	☐	☐ A ☒ B

7. RF FIELD STRENGTH SUSCEPTIBILITY TEST

7.1. Block Diagram of Test Setup



7.2. Test Standard

EN IEC 61547: 2023 (EN 61000-4-3: 2020, Severity Level: 2, 3V / m)

7.3. Severity Levels and Performance Criterion

7.3.1. Severity level

Level	Field Strength (V/m)
1	1
2	3
3	10
X	Special

7.3.2. Performance criterion: A

7.4.EUT Configuration on Test

The configuration of EUT are listed in Section 2.1.

7.5.Operating Condition of EUT

7.5.1.Setup the EUT as shown in Section 7.1.

7.5.2.Turn on the power of all equipments.

7.5.3.Let the EUT work in test mode (On) and measure it.

7.6.Test Procedure

The EUT and its simulators are placed on a turn table which is 0.8 meter above ground. EUT is set 3 meter away from the transmitting antenna which is mounted on an antenna tower. Both horizontal and vertical polarization of the antenna are set on test. Each of the four sides of EUT must be faced this transmitting antenna and measured individually. In order to judge the EUT performance, a CCD camera is used to monitor EUT screen. All the scanning conditions are as follows:

Condition of Test	Remarks
-----	-----
1. Fielded Strength	3 V/m (Severity Level 2)
2. Radiated Signal	Unmodulated
3. Scanning Frequency	80 - 1000 MHz
4. Dwell time of radiated	0.0015 decade/s
5. Waiting Time	3 Sec.

7.7.Test Results

PASS.

Please refer to the following page.

RF Field Strength Susceptibility Test Results

Standard	☐ IEC 61000-4-3 ☒ EN 61000-4-3		
Applicant	Sonway Co.,Limited		
EUT	Recessed Swimming Pool Light	Temperature	26℃
M/N	B4FE1819 D	Humidity	51%
Field Strength	3 V/m	Criterion	A
Test Mode	ON	Test Engineer	Gao
Frequency Range	80 MHz to 1000 MHz		
Modulation	☐ None ☐ Pulse ☒ AM 1KHz 80%		
Steps	1%		

	Horizontal	Vertical
Front	PASS	PASS
Right	PASS	PASS
Rear	PASS	PASS
Left	PASS	PASS


Test Equipment:

1. Signal Generator: 2031 (MARCONI)
2. Power Amplifier: 500A100 & 100W/1000M1 (A&R)
3. Power Antenna: 3108 (EMCO) & AT1080 (A&R)
4. Field Monitor: FM2000 (A&R)

Note:

8. MAGNETIC FIELD IMMUNITY TEST

8.1. Block Diagram of Test Setup



8.2. Test Standard

EN IEC 61547: 2023 (EN 61000-4-8: 2010, Severity Level 2: 3A/m)

8.3. Severity Levels and Performance Criterion

8.3.1. Severity level

Level	Magnetic Field Strength (A/m)
1.	1
2.	3
3.	10
4.	30
5.	100
X	Special

8.3.2. Performance criterion: A

8.4. EUT Configuration on Test

The configuration of EUT are listed in Section 3.12.

8.5.Operating Condition of EUT

8.5.1.Setup the EUT as shown in Section 8.1.

8.5.2.Turn on the power of all equipments.

8.5.3.Let the EUT work in test mode (On) and measure it.

8.6.Test Procedure

8.6.1.Set up the EUT system as shown on Section 8.1.

8.6.2.The Induction coil is set up in horizontal or vertical.

8.6.3.Let the EUT work in test mode and measure it.

8.7.Test Results

PASS.

Please refer to the following page.

Magnetic Field Immunity Test Result


Standard	☐ IEC 61000-4-8 ☒ EN 61000-4-8		
Applicant	Sonway Co.,Limited		
EUT	Recessed Swimming Pool Light	Temperature	26℃
M/N	B4FE1819 D	Humidity	51%
Test Mode	ON	Criterion	A
Test Engineer	Gao		

Test Level (A/M)	Testing Duration	Coil Orientation	Criterion	Result
3	5 mins	X	A	PASS
3	5 mins	Y	A	PASS
3	5 mins	Z	A	PASS

Note:

9. PHOTOGRAPH

9.1.Photo of Radiated Measurement



9. EXTERNAL AND INTERNAL PHOTOS OF THE EUT

B4FE1819 D PHOTOS



Fig. 1



Fig.2




Fig.3



Fig.4

-----THE END OF REPORT-----